

Power load flow analysis

A case for power Distribution Network of Federal University of
Technology Minna.

By

OYEDOTUN ADEDEMI AKINROPO
PGD/MCS/107/93/94

Department of Mathematics/Computer Science
School of Science and sciences Education
Federal University of Technology,
Minna, Nigeria

A project submitted to the Department of
Mathematics/Computer science in
partial fulfillment of the requirement for
the award of a post-graduate Diploma in computer science

March - 1998

APPROVAL PAGE

We hereby certify that we have supervised, read & approved this project work which we found to be adequate in scope and qualified for partial fulfilment of the award of a Post - Graduate Diploma in computer science (PGD in Computer Science).

Sign_____

Date_____

Dr. Yomi Aiyesimi
(Project Supervisor)

Sign-----

Date-----

DR. K. R. Adeboye
(Head of Department)

Sign_____

Date_____

(External Examiner)

DEDICATION

This project is dedicated to almighty Allah for giving me the opportunity to complete this project successfully.

TABLE OF CONTENTS

Title Page.....	i
Approval Page.....	ii
Declaration.....	iii
Dedication.....	iv
Acknowledgement.....	v
Table of Contents.....	vi
Abstract.....	vii
CHAPTER I	
Introduction.....	1
Need for load flow analysis.....	2
CHAPTER II	
Load flow analysis of F. U. T. Minna.....	4
Load consumption of F. U. T. Minna.....	8
CHAPTER III	
System Analysis and Design.....	10
Mathematical Model.....	12
Numerical Solution Techniques.....	14
Guess Iterative Method.....	15
Newton Raphson Method.....	16
CHAPTER IV	
Programming Languages.....	17
Programming of Power Load Flow.....	18
Types of Electrical Networks.....	18
Federal University of Technology Distribution Network & choice of programming Language.....	19
Flow Charts & Programming	20 - 36
Analysis of Results	37

CHAPTER V

Recommendations	38
Conclusion.....	39
References.....	40

ACKNOWLEDGEMENT

I must sincerely express my thank to almighty God for the protection and guidance throughout the period of the course in Post-graduate Diploma in computer science.

I wish to register my profound appreciation to DR. Yomi Aiyesimi(Supervisor of this project), Dr. K. R. Adeboye (Head of Mathematics/Computer science), Prince R. O. Badamosi (Course Co-ordinator) and Dr. S. A. Reju for their contribution in making this project a reality.

My special thanks to Mallam I. M. Kuta (Director of works), Engr I. B. Musa (Principal Civil Engineer, Arch. U. B. Jibril (Principal Architect), Mrs, V. Kolo (personal secretary to Director of works) and Mallam Adamu- Danjuma for their immense contribution to the success of this project.

I am also grateful to Engr. (Dr) F. Akinbode, (Head of mechanical department), Mr. Vincent Ogwuagwu and Engr. Y. A. Adediran for their moral support throughout the project.

Finally, I wish to express my gratitude to Mrs F. B. Oyedotun (my wife), and Mallam Y. A. Mohammed of library department for their unflinching support during the course.

I shall forever be grateful to all those mentioned above.

Adefemi Akinropo Oyedotun

ABSTRACT

The main objective of this project is to analyse the electrical load flow pattern of the distribution network of Federal University of Technology Minna. To establish a load flow pattern that may be projected with the use of computer.

The electrical network consists of six busbars, two distribution substations which contain 2x500KVA, 11/0.415KV step down transformers, located within the load centers of the university. Each busbar has an upriser armoured cables serving different section of the university.

The values of the busbars and line parameters are calculated on a bases of 11KV, 2x500 KVA (1.0MVA). In the electrical distribution network, there are no regulating or phase shift transformers and capacitor bank which can serve as voltage of control buses.

Numerical computation of busbar voltage is based on gauss iterative techniques after a thorough comparison with Newton iterative technique.

A computer program is written in Qbasic language for easy understanding. A flow chart is drawn from the solutions of the network equations

CHAPTER 1

Introduction:

1. The appearance of large digital computer in the early 1960's paved the way for its application to power system analysis. There is the need to provide a more reliable, stable and economic supply of electrical energy with tighter control of the system frequency and voltage levels.

2. It is often realized that the optimal power flow needs to be iterated with contingency analysis. The purpose of an on - line function is to schedule the power system controls to achieve a desire operation of power flow.

3. Having considered the above analysis, load flow in power system is very important and there is need for a thorough appraisal of electrical load flow network. Because of the complex nature of electrical load flow analysis, computer application has helped in the power system design, analysis and operation of any electrical network. A more realistic approach and solution is obtained with computer application and engineers are totally relieved of tedious and volume of calculations. Computer capability is to minimize the number of manual operation required by the engineers in specifying and maintaining system data for the initial and subsequent electrical load flow cases.

The application of computer to electrical load flow requires sequential steps which must be obeyed in order to computerise the load flow analysis.

- (a) The formulation of a suitable mathematical network model which describes adequately the relationship between voltages and power in the system.
- (b) Specifications of the power and voltage constraints that must be applied to the various busbars of the network.
- (c) Numerical solution of the load flow equations subject to the power and voltage constraints.
- (d) When all these voltages have been determined, the last step is the calculation of load flows on the various network lines.

Consumption pattern enables the Engineers to study the power consumption in the specific network and forecast the load consumption so that the contingency plan can be made for future. This will facilitate their use in power system planning, operation and interconnection studies. The transformer's load can be monitored so that overload transformers can be protected from total breakdown.

NEED FOR LOAD FLOW ANALYSIS:

Load flow studies enable the power system Engineers to make a projection of future power requirements and incorporate or create room for additional or changes in load requirement during the system planning stages of electrical power supply.

Satisfactory operation of the power system depends on system network and new load which needs to be added to the existing load of the power network. The resultant effect from load flow calculation filter out real and reactive power which are simply called useful and useless power.

The load flow analysis helps to know whether the existing transformers and lines are overloaded and to prevent total collapse of the power network. The load flow analysis takes care of the following:

- (a) Additional transformers and lines may be required as a result of expansion.
- (b) Changes of load may affect the busbars and conductor sizes. The load flow analysis will take care of that.
- (c) Load flow incorporates many automatic features to facilitate their use in power system planning, design, operation and interconnection studies.
- (d) On - line applications of automatic control and system optimization.
- (e) Load flow helps to detect any short- circuit and system instability in the network.
- (f) Once a computer program has been written on power load flow of a system, the input data on the increased or decreased depending on the system requirements.
- (g) Load flow analysis can also be used to study an industrial power system under transient loads. This is essential in determining whether loads can be imposed on an existing power system design.

CHAPTER 2

2.1 LOAD FLOW ANALYSIS OF FEDERAL UNIVERSITY OF TECHNOLOGY MINNA.

The analysis on the load flow pattern of this electrical distribution network of the campus can best be described by a one line diagram shown in fig 1.

An 11Kv transmission line from Minna entered the campus through the main gate. A ring main unit device located near the gate for easy isolation of electrical network of the campus. Two numbers of distribution transformers (500KVA, 11/0.415KV) are located at the load centers of the university.

- (i) The first sub-station with a transformer is located near the university clinic. A 365KVA catapillar generator is attached to this sub-station to provide an alternative power to the essential load within the university. The three upriser feeders came out from the substation to feed the electric load in different section of the university.
- (a) An upriser feeder - line - one consists of the following load: Computer center and senate building. A load flow analysis would be considered for upriser feeder which will take care of the attached mentioned load.
- (b) An upriser feeder - liner - tow consists of library, water pump, audit unit, biological sciences block and Dean of SSSE block. A load flow analysis would take care of the above mentioned load in upriser feeder two.
- (c) An upriser feeder - line - three consists of female hostel, block D classroom, Mathematics department, staff quarters and

ONE LINE ELECTRICAL DIAGRAM FOR FEDERAL UNIVERSITY OF TECHNOLOGY, MINNA . BOSSO CAMPUS




Fig.1

clinic: A load flow analysis would also be considered.

- (ii) The second sub - station with a transformer is located near cafeteria to take care of the load with in that section of the university. The three uprises feeder lines also emanated from this sub - station.
- (a) An uprises feeder line-one consists of the Engineering complex block, Lecture theaters, Geology laboratories, physics laboratories, block of offices for SSSE and staff school. This is the longest uprises feeder line in the university. A load flow analysis is written for that:
- (b) An uprises feeder line-two consists of the male hostels, cafeteria, engineering block offices and school of Environmental. A load flow analysis is written.
- (c) An uprises feeder line - three consists of the works department, kiosks and animal garden area. A load flow analysis would be considered.

A load flow analysis for this university would consists of 2 NO of Distribution transformers, 6NO of uprises feeder lines and cabling to feed the above mentioned load. Six busbars (buses) would be used in load flow analysis. the Parameters and the required data for SIX buses which are essential in the computer application of load flow analysis.

The data below are obtained from feeder lines for the two substations. Each feeder line would represent a busbar.

Line	feeder	Busbar	Load	Load	Load	Areas cover
			KVA	KW	Ampere	
M	M					
1	1	1	277.5	222	400	senate comp
2	2	2	145.8	116.7	210	Lib. & SSSE
3	3	3	69.4	55.5	100	Female Hos.
4	4	4	101.5	81.2	146	Staff school
	5	5	84.5	67.6	122	Male hostel
6	6	6	42.9	34.3	62	Works dept
			721.KVA			

2.2 CALCULATION OF BUS DATA SPECIFICATION

The total installed power from the two transformers is 1000 KVA which is 1MVA. This will be used as base power and feeder load will be referred to base power as per unit form.

The assumed power factor of 0.8 in a stable and reliable network is considered.

The real power is called useful power while the reactive power is relatively termed to be useless power.

The per-unit calculation can be expressed as shown.

feeder 1.

$$\text{Total power} = 277.5 \text{WA}$$

$$= 0.2775 \text{MVA}$$

$$\text{Per - unit} = 0.2775 \text{MVA} / \text{base power}$$

$$= 0.2775 \text{MVA} / 1 \text{ MVA}$$

$$= 0.2775$$

$$\text{Real power} = 0.2775 \cos 36.9^\circ = 0.222$$

$$\text{Reactive power} = 0.2775 \sin 36.9^\circ = 0.222$$

The power can be written as 0.222 + j0.166

feeder 2

$$\begin{aligned} \text{Total power} &= 145.8 \text{KVA} \\ &= 0.1458 \text{ MVA} \end{aligned}$$

$$\begin{aligned} \text{Per Unit} &= 0.1458 \text{MVA}/1 \text{ MVA} \\ &= \underline{0.1458} \end{aligned}$$

$$\text{Real power} = 0.1458 \cos 36.9 = 0.1166$$

$$\text{reaction power} = 0.1458 \sin 36.9 = 0.0875$$

The power can be written as $0.1166 + j0.0875$

feeder 3

$$\begin{aligned} \text{Total power} &= 69.4 \text{ KVA} \\ &= 0.0694 \text{ MVA} \end{aligned}$$

$$\begin{aligned} \text{per unit} &= 0.0694 \text{MVA}/1 \text{ MVA} \\ &= 0.0694 \end{aligned}$$

$$\text{Real power} = 0.0694 \cos 36.9^\circ = 0.0555$$

$$\text{Reactive power} = 0.0694 \sin 36.9^\circ = 0.0416$$

The power can be expressed as $0.555 + j0.0416$

feeder 4

$$\begin{aligned} \text{Total power} &= 101.5 \text{KVA} \\ &= 0.1015 \text{MVA} \end{aligned}$$

$$\begin{aligned} \text{Per - unit} &= 0.1015 \text{MVA}/1 \text{ MVA} \\ &= 0.1015 \end{aligned}$$

$$\text{Real power} = 0.1015 \cos 36.9 = 0.0812$$

$$\text{Reactive power} = 0.1015 \sin 36.9 = 0.0610$$

The power can be expressed as $0.0812 + 0.0610$

feeder 5

$$\begin{aligned}\text{Total power} &= 84.5\text{KVA} \\ &= 0.0845 \text{ MVA}\end{aligned}$$

$$\begin{aligned}\text{Per - unit} &= 0.0845\text{MVA}/1 \text{ MVA} \\ &= 0.0845\end{aligned}$$

$$\text{Real power} = 0.0845 \cos 36.5^\circ = 0.0676$$

$$\text{Reactive power} = 0.0845 \sin 36.5 = 0.0507$$

The power can be expressed as

$$0.0676 + j0.0507.$$

feeder 6

$$\begin{aligned}\text{Total power} &= 42.9\text{KVA} \\ &= 0.429\text{MVA}\end{aligned}$$

$$\text{Per unit} = 0.0429\text{MVA}/1 \text{ MVA} = 0.0429$$

$$\text{Real power} = 0.0429 \cos 36.9^\circ = 0.0343$$

$$\text{Reactive power} = 0.0429 \sin 36.9^\circ = 0.0257$$

The power can be expressed as

$$0.0343 + j0.0257$$

Load consumption of Federal University of Technology Minna

A consumption pattern could be analyzed from the year the university was established up to date. The university was established in 1983 and there was only one substation existing at that time. In 1985, the second sub - station was built which takes care of electrical load at the down stream side of the university. The table below shows the load consumption pattern in kilowatt for both transformers

|Load consumption in KW

Year	Sub-station 1	Sub-station 2
1983	19.59 KW	-
1984	147.16 "	-
1985	315.69 "	32.0 Kw
1986	300.00 "	119.20
1987	300.00 "	180.86
1988	320.00 "	205.67
1989	320.00 "	284.05
1990	320.00 "	300.55
1991	320.47 "	300.55
1992	330.17 "	300.55
1993	330.17 "	320.65
1994	340.17 "	330.55
1995	350.46	330.55
1996	360.46	330.55

CHAPTER 3

(i) SYSTEM ANALYSIS AND DESIGN.

The load flow analysis problem consists of the calculation of power flow and voltages of the electrical distribution network for specifies busbars condition.

The associated parameters of busbars are

- (1) Real power (useful power)
- (2) Reactive power (useful power)
- (3) Voltage magnitude
- (4) Phase angle.

The load flow analysis can be formulated in its basic analytical form with reference to network which can be represented by linear bilatered and balanced lumped parameters. The power and voltage constraints make it the nonlinear in nature. The numerical solution must be iterative in nature.

The electrical current problem encountered in the development of load flow are ever increasing size of the systems to be solved, on-line applications and system optimization.

Five main properties are essential in load flow solution method.

- (a) High computational speed: This is very important when dealing with large system, real time applications i.e. on - line application and interactive application i.e. off - line application.
- (b) Low computer storage:- This is also important for large electrical systems and the use of computers with small core storage available, e.g. mini computer for on - line

application.

- (c) Reliability of solution: The solution of load flow must be obtained for both ill- conditioned problem, outage studies and real life time application
- (d) Versatile: An ability of load flow analysis to handle conventional and special features.
- (e) Simplicity: The ease of coding a computer program of the load flow algorithm.

The type of solution required for a load flow also spell out the method apply which satisfies the following condition.

- (i) Accurate or approximate
- (ii) Unadjusted or adjusted
- (iii) Off - line or on - line
- (iv) Simple case or multiple case

For an unbalanced three phase system, each busbar consists of three single - phase bus and six equation which has to be solved by load flow analysis. For a balanced three phase system, a one line diagram is always used to represent a complete 3 - phase system. It consists of a diagram identifying busbars and connecting lines with loads and transformers in their respective places in the system. Each interconnecting lines originate from a particular bus and terminates on a different bus.

Load flow calculations can be solved by using bus self and mutual admittance which compose of bus admittances. In the calculation of load flow, the following information are essential.

- (a) One line diagram of the system network. Also positive

sequences diagram.

- (b) Oriented graph showing tree, cotree, links, cutset and loops.
- (c) The values of series impedances and shunt admittances of transmission lines or distribution network from these values of busbar admittance or bus impedance matrix elements can be calculated.
- (d) Transformer ratings
- (e) The value of reactive power and voltage magnitude at each bus
- (f) The limitation of voltage magnitude and reactive power must be clearly stated. the voltages and powers at the busbar must lie within the range of an interval.
 - (i) Voltage minimum < voltage level < voltage max.
 - (ii) Power minimum < power level < power max
 - (iii) Reactive power mini < per power level < reac. power max.

3.1 LOAD FLOW ANALYSIS MATHEMATICAL MODEL.

A matrix equation always provide a convenient mathematical model for computational analysis. The elements of the matrix equation are impedances and admittances.

The nature of matrix will depend on the number of busbars and their looping. It is always convenient to assign bus number, line number and the form of the appropriate network matrix in the load flow analysis.

Basic loops of the network are identify first. The formulation

The elements at zero busbar are neglected or considered as one element and is equivalent to all the zero busbar elements. With this method, computer storage time can be conserved.

Any node A of the network for the total is given by

$$I = Y_{AR} V_R$$

$$A = 1, 2, 3, \dots, n \} \text{ -----} \rightarrow 2d$$

$$R = 1, 2, 3, \dots, n \}$$

$$I_A = P_A - Q_R/V_A$$

Equation 2e can be re-written as

$$P_A - jQR = Y_{AR} V_R V_A$$

$$P_A - jQR = Y_{AR} V_R V_A = 0 \text{ -----} \rightarrow 2f$$

where P_A = Active power

Q_R = reactive power

Y_{AR} = Line admittance between A and R

$V_R V_A$ = Voltages at busbars A and R respectively.

3.2 NUMERICAL SOLUTION TECHNIQUES

The algebraic equations for the power load flow are based on iterative techniques because of their non-linearity in nature. The iterative methods are specifically designed to compute accurate estimates of unknown voltages until the results are obtained to the desired accuracy. This is done in a finite number of iterations. It has been established that the busbar equations must satisfy Kirchhoff's laws. The laws are:

- (a) The algebraic sum of currents flow at a busbar must be equal to zero.
- (b) The algebraic sum of all voltage in a loop must also be

equal to zero

The above laws are used for convergence of the solution in the iterative computational method. The most common iterative methods are.

- (i) The Gauss iterative method
- (ii) The Newton - Raphison method.

These iterative methods are analysis below.

(i) GAUSS ITERATIVE METHOD

The Guass iterative method was used for load flow. The computational procedure usually follow a set of algorithm for computer execution. The calculation of load equations follows some series of steps which are

(a) Read in the following numerical values of

- (i) Length
- (ii) Impedance
- (iii) Number of busbars
- (iv) Number of line
- (v) Acceleration factor
- (vi) Busbar power

(b) Assembly the 'y' Bus admittance matrix and the iterative solution of the bus voltages

$$V_p = 1/Y_{p1} (I_p - E Y_{p1} V_1) \text{-----}(1)$$

$$I_p = P_p - JQ_p / V_p \text{-----}(2)$$

$$V_p = 1/Y_{p1} [P_p JQ_{ip} E Y_{p1} V_1$$

$$V_p = 1/Y_{p2} [P_p JQ_{2p} /vpk E Y_{p2} \text{-----}>(3)$$

This iterative process will continue until the magnitude of

the change of the bus voltage between two consecutive iteration is less than certain tolerance level for all the bus voltages.

When the iterations have converged, the next step is to calculate the value of slack bus power given by:

$$S_i = P_i + jQ_i \text{ -----> (4)}$$

The final step is the calculation of load flows on various distribution lines of the network. this can be expressed as

$$S_{ij} = P_{ij} + jQ_{ij} = V_i (V_i - V_j) Y_{ij} + V_i V_i Y_{ij}$$

This expression is from buses i to j

(ii) Newton - Raphson method:

The Newton - Raphson method is tested to be the most sophisticated of the iterative techniques and it converges faster without the risk of divergence than the Gauss method.

The rate of convergence can be increased by applying an acceleration factor to the approximate solution obtained from each iteration. The accelerated values of voltages are given by

$$V_p = V_p + \alpha (V_p - V_p)$$

where k = iteration count

α = acceleration factor.

The acceleration factor is between 1.5 and 1.7 for both real and imaginary.

CHAPTER 4

4.1 PROGRAMMING LANGUAGES

High level programming languages can be classified into scientific oriented languages, business oriented language specific purpose language and multi-purpose language.

(i) SCIENTIFIC ORIENTED LANGUAGES

These languages are designed for scientific and engineering applications and therefore they contain a lot of mathematical expressions for complex calculation.

Examples of such languages are Basic, ALGOL, and FORTRAN.

(ii) BUSINESS ORIENTED LANGUAGES

The most popular of business oriented languages is COBOL. These languages can only accommodate few simple mathematical and provide extensive filing system,

(iii) SPECIAL PURPOSE LANGUAGES.

These languages are specially designed for some particular types of problems. Example of these language is CSL - computer simulation language CORAL-66 - design for direct control of physical processors. Scientific and engineering control experiments.

(iv) MULTI - PURPOSE LANGUAGES:

These languages are designed to solve scientific and business applications. Example of such language is PASCAL . Pascal language was designed to be a structured language. The purpose is to encourage the building of good programs. The program language is efficient on present day computers. The language is widely used up

till today.

PROGRAMMING OF POWER LOAD FLOW

The two languages applicable for power load flow are BASIC and FORTRAN. These languages are good for engineering applications such as power load flow in electrical engineering profession.

TYPE OF ELECTRICAL NETWORK

There are six types of network

- (a) 415V low tension line network
- (b) 11KV medium line network
- (c) 33KV Transmission line network
- (d) 66Kv Transmission line network
- (e) 132KV Transmission line network
- (f) 330 KV transmission line network

11KV and 33KV line network

The 11KV and 33KV lines have resistance, inductance and capacitance parameters. Because of distance design to cover ,capasitance and inductance are considered as inactive parameters along the transmission lines. FORTRAN language is suitable for the line.

66KV 132KV and 330KV transmission line

The 66KV, 132KV and 330KV have resistance, inductance and capacitance parameters These parameters are active because of the distance and power involved at the load centers (Users).

The mathematical expression for voltages and power involve imaginary parameters and 'j' must be used as operator. In order to

handle such engineering problems with imaginary roots, FORTRAN program language will be convenient to solve such a complex mathematical expression.

415V LOW TENSION LINES

The 415V lines have resistance, inductance and capacitance along the lines. These parameters are considered inactive except resistance because of the small distance designed to cover and power meant to be transferred to load centers (users).

Basic programming language is quit suitable for power load flow of this kind of line.

4.3 FEDERAL UNIVERSITY OF TECHNOLOGY DISTRIBUTION NETWORK AND THE CHOICE OF PROGRAM LANGUAGE.

Federal university of technology electrical distribution network is on 415V low tension lines. These run into the load centers (users) within the university system.

In developing the programming language for this, a BASIC program language is deemed fit to solve the power load flow analysis because the imaginary parameters such as inductance and capacitance are assumed to be inactive.

There are six distribution lines and each line serves a particular load center. For simplicity, a program has been written for each line. The limiting voltage is determined by using Gauss seidel iteration method. the power flow available at the load center is determined.

PROGRAM 1

This program is to determine the main admittance (Y_{nn1}) for the network. A program is written to solve the "Determinant" of the

network.

PROGRAM 2 This program is to determine the voltage and power available to senate building and computer center of the university. A gauss seidel iteration program is written to determine the voltage available to the users. The iteration voltage simply called limiting voltages which is 397V and power flow along the line is 158.80KW.

PROGRAM 3

This program is to take care of voltage and power available at university water pump, library and part of school of science and science education. The iteration voltage for the line is 400.7v and the power flow along the line is 84.15KW.

PROGRAM 4

This program is designed to take care of voltage and power flow along the female hotels, clinic and staff-quarters. The iteration voltage for the line is 399V and power flow along the line is 39.89KW.

PROGRAM 5

This program is designed to take care of voltage and power flow available to the users along the line serving the staff school, lecture theater and engineering complex. The iteration voltage is 402V while the power flow along the line is 58.8KW.

PROGRAM 6

The program is designed to take care of voltage and power flow available to the users along the line serving the male hostel, cafeteria and environmental technology. the iteration voltage is

404V while the power flow along the line is 48.6KW.

PROGRAM 7

The program is designed to take care of voltage and power flow available to the users along the line serving the Works and Maintenance department, Kiosk and Animal garden. The iteration voltage is 411V while the power flow along the line is 25.5KW.

4.4 The table below shows the detail result of all the programs in relation to the feeder lines fig. 4.1.

<u>line</u>	<u>NAME OF FEED.</u>	<u>DIST. (KM)</u>	<u>LOAD CUR.A</u>	<u>NO OF ITER</u>	<u>LIM.VOL.</u>	<u>LO.POWER</u>
1	Senate/comput center	0.25	400	4	397	158.8
2	Water pump/ library/SSSE	0.75	210	6	401	84.2
3	Female hostel clinic/staffq	0.4	100	4	399	39.9
4	Staff school/ LT/Eng.Comp	1.5	146	4	402	58.8
5	Male/hostel/ caf/envir/co	0.6	122	5	404	48.6
6	works dept/ animal garden	0.3	62	5	411	25.5

MAIN BUSBAR






Fig.4.1

Program 1
Flow Chart Diagram




Program 2

Flow chart Diagram




4.8 Program 3


Flow chart diagram



4.9 Program 4
Flow chart diagram




4.10 Program 5
Flow chart diagram



4.11 Program 6
Flow chart diagram

Start



4.15 Program 2

```
' Power load flow analysis for senate building and computer
centre
  Input "Enter maximum voltage"; Vnn
  Input "Enter Distance A"; Dis.A
  Input "Enter voltage at Main busbar"; Vn
  Input "Enter line current A"; IA
  Input "Enter power at main busbar.; P
  Input "Enter Determinant"; Det 1
Ynni = Det 1 * dis. A
Print "Admittance = "; Ynni
for i = 1 to 5
Vnoai = (1/Ynni) * ((P/Vni) - (Ynni * Vni))
  Vni = Vnoai
Print "Vnoai"; i, "="; Vnoai, "V"
IF (Vnn - Vnoai)/Vnn >= 0.05 Then goto 100
  Next
100 print "Limiting voltage = "; Vnoai "V"
Print "No of iteration = "; i
Pna = (Vnoai * IA)/1000
Print " Power at busbar A = ", Pna; "KW"
End
Stop
```

Results

```
Admittance = 2.90000
Iteration voltage = Vnoa1, Vnoa2, Vnoa3, Vnoa4
                  415.9V, 413.2V, 421.4V, 397V
Limiting voltage = 397V
No of iteration = 4
Power at Busbar A = 158.8KW
```

Program 3

```
cls
'Power load flow analysis for Water pump, Library and SSSE
Input "Enter maximum voltage"; Vnn
Input "Enter Distance B"; dis.B
Input "Enter voltage at main busbar"; Vni
Input "Enter line current B"; IB
Input "Enter power at main busbar"; P
Input "Enter Determinant "; Det 1
Det 2 = det1/2.997
Ynn2 = det 2 * dis.B
Print "Admittance ="; Ynn2
for i = 1 to 7
Vnobi = (1/Ynn2) * ((P/Vni) - (Ynn2 * Vni))
  Vni = Vnobi
  Print "Vnobi" i, "="; Vnobi "V"
IF (( Vnn -Vnobi)/Vnn) > = 0.05 Then goto 200
Next
200 print "Limiting voltage = "; Vnobi; "V"
Print "No of Iteration =";
Pnb = (Vnobi * IB)/1000
Print "power at Busbar B = " Pnb; "KW"
End
Stop
```

Results

Admittance = 2.902903
iteration voltages = V_{nob1} = 415.1v, V_{nob2} = 414.8v, V_{nob3} = 415v,
V_{nob4} = 413.4v, V_{nob5} = 4198v V_{nob6} = 401v
Limiting voltage = 401v
No of iteration = 6
Power at Busbar B = 84.2 KW

4.17

program 4

```
cls
'Power load flow analysis for female hotels, Clinic and Staff
quarters
Input "Enter maximum voltage"; Vnn
Input "Enter distance C"; dis.C
Input "Enter voltage at main busbar"; Vni
Input "Enter line current C". Ic
Input "Enter power at main busbar". P
Input "Enter Determinat"; Det 1
Det 3 = Det1/1.5998
Ynn3 = Det 3 * dis.C
Print "Admittance ="; Ynn3
for i = 1 to 5
Vnoci = (1/Ynn3) * ((P/Vni) - (Ynn3 * Vni))
  Vni = Vnoci
print "Vnoci"; i' "="; Vnoci "V"
IF (( Vnn - Vnoci)/Vnn ) > + 0.05 Then goto 300
Next
300 Print "Limiting voltage = "; Vnoci; "V"
print "No of iteration = "; i
Pnc = (Vnoci * IC)/1000
print "Power at Busbar C = "; Pnc ; "kw"
End
Stop
```

Results

Admittance =2.900363
Iteration voltages = V_{noci} = 415.8V, V_{noci2} = 413.4V, V_{noci3} = 420.6V
V_{noci4} = 399V
Limiting voltage = 399V
No of iteration = 4
Power at busbar C = 39.9kw

rogram 5

ower load flow analysis for Staff school, Lecture theaters and
ngineerig Complex

```
nput "Enter maximum voltage"; Vnn
nput "Enter distance D"; dis D
nput "Enter voltage at main busbar"; Vni
nput "Enter line current D"; I0
nput "Enter Power at main busbar ; P
nput "Enter Determinant"; Det1
et 4 = Det1/5.998
nn4 = Det 4 * dis.D
rint "Admittance = ; Ynn4
or i = 1 to 4
nodi = (1/Ynn4 ) * ((P/Vni) - (Ynn4 * Vni))
Vni = Vnodi
rint "Vnobi"; i' "="; Vnodi "V"
F ((Vnn - Vnodi)/Vnn) > = 0.05 Then goto 400
Next
00 print "Limiting voltage + "; Vnodi; "V"
Print "No pf iteration ="; i
Pn0 = (Vnodi * I0)/1000
Print " Power at Busbar D = "; Pn0 "kw"
End
Stop
```

esult

```
dmittance = 2.900967
teration voltage = Vn0d1 = 415.6V, Vn0d2 = 413.7V
Vn0d3 419.4V, Vn0d4 = 402V
imiting voltage = 402V
o of iteration 4
ower at Busbar D = 58.8kw
```

Program 6

```
Cls
'Power load flow analysis for male Hostels, Cafeteria and
Environmental complex
Input "Enter maximum voltage"; Vnn
Input "Enter Distance E"; dis E
Input "Enter voltage at main busbar"; Vni
Input "Enter line current E"; Ie
Input "Enter power at main busbar"; P
Input "Enter Determinant "; Det 1
Det 5 = Det 1/2.399
Ynn5 = Det 5 * dis E
Print "Admittance +"; Ynn5
for i = 1 to 5
Vnoei = (1/Ynn5) * ((P/Vni) - (Ynn5*Vni))
  Vni = Vnoei
print "Vnoei "; i, " = "; Vnoei, "V"
IF (( Vnn - Vnoei )/Vnn) > = 0.05 Then goto 500
Next
500 print "limiting voltage ="; Vnoei; "V"
print "No of iteration ="; i
Pne = (Vnoei * Ie)/1000
Print "power at busbar E ="; Pne "kw"
End
Stop
```

Results

```
Admittance = 2.901209
iteration voltage =Vnod1 415.6 Vnod2 = 413.9V, Vnoe3 = 419V
  Vnoe4 = 404V
  Limiting Voltage = 404V
  No of iteratron = 4
  power at Busbar E = 48.5 Kw
```


4.20 Program 7

```
cls
'Power load flow analysis for Works and maintenance and Animal
production departments.
Input "Enter maximum voltage"; Vnn
Input "Enter distance F"; dis.F
Input "Enter voltage at main busbar"; Vni
Input "Enter Line current F "; Ix
Input "Enter power at mains busbar"; P
Input "Enter Determinat"; Det 1
Det 6 = Det 1/1.99
Ynn6 = det 6 * Dis.F
Print "Admittance ="; Ynn6
  For i = 1 to 5
Vnofi = (1/Ynn6) * ((P/Vni) - (Ynn6 * Vni))
  Vni = Vnofi
Print Vnofi "; i; "="; Vnofi; "V"
IF (( Vnn - Vnofi )/Vnn ) = 0.05 Then goto 600
Next
600 print "limiting voltage ="; Vnofi;"V"
print "No of iteration ="; i
Pnf = (Vnofi * Ix)/1000
Print "Power at Busbar F="; Pni "kw"
End
Stop
```

RESULTS

```
Result
Admittance = 2.902419
iteration voltage =Vnof1 415.2v,Vnod2 = 414.6v Vnod3 416.5v,Vnod4
= 411v
  No of iteration = 4
  Limiting voltage = 411v
  Power at Busbar F = 25.5kw
```

4.21 ANALYSIS OF RESULTS FROM COMPUTER PROGRAM

The program solution for power load flow of federal university of technology, Minna is shown in Programs 1 - 7 (Computer result)

The iteration voltages obtained for six lines are reasonable. It values show that there are voltage drops along the lines. See fig 4.1

The power load flow results for each line are accurate when load flow results The power load flow for senate building and computer centre is the highest.

5.0

CHAPTER 5

5.1

RECOMMENDATIONS

The following recommendations are considered necessary in order to operate, maintain, plan and design the power load flow of federal university of technology Minna.

- (i) The conductor's route must be accurately surveyed in order to get accurate distance for each line
- (ii) The size of conductors used now need to be changed in order reduce the voltage drops along the line especially senate building and computer centre.
- (iii) Preparation for additional transformer is considered necessary because of non-utilization of electrical machines at school of engineering
- (iv) Planning, design, operation and maintenance of the existing and new lines are easy with the use of computer program but there is the need to open a data bank so that any change in input data can be reflected in the data bank.
- (v) Load projection is necessary in order to avoid the overload of the existing transformers.

5.2 CONCLUSION:

The information obtained from the computer program is an indication that digital computer is an indispensable tool in engineering field. Engineers are relieved of tedious normal calculations. Once the program is written, for power load flows, future load flow can easily be obtained by updating the input load current and length of the lines.

REFERENCES

1. Anthony, J. P. Electrical Distribution Engineering. New York:Mcgraw Hill, 1986.
2. Arrillaga, J. et. al. Computer Analysis of Power Systems. New York:John Wiley & Sons, 1990.
3. Badmus, R. O. Lecture Notes on System Analysis & Design (unpublished) 1996.
4. Cotton, H. et. al. The Transmission & Utilization of Electrical Power . London:Hodder & stoughton Educ., 1978.
5. Glenn, W. S. Computer Methods in Power System Analysis. London: Mcgraw Hill, 1988.
6. Leon, K. K. Economic Operation of Power Systems .New York: Wiley Eastern Ltd., 1979.
7. Olle, I. E. Basic Electrical Power Engineering. London: Addison _Wesley, 1977.
8. Uwaifo, S. O. Electric Power Distribution, Planning and Development. Lagos: Malthouse, 1994
9. Wadhwa, C. L. Electrical Power Systems. New Delhi: Wiley Eastern Ltd. , 1991.
10. Weedy, B. M. Electric Power Systems. Great Britain: John Wiley & Sons, 1992.