

1. **The Kaduna Electricity Distribution Company (KEDCO)** is one of the eleven distribution companies that manage the electrical power distribution system in four states, namely Kaduna, Kebbi, Sokoto and Zamfara states respectively. It has total number of eight thousand two hundred and seventy-three (8273) transformers, one hundred and thirteen (113) injection substations and eleven thousand two hundred and forty-seven (11,247) distribution substations across the state (KEDCO, 2016). Furthermore, it has power routine line of (9,467) of 33kv (2,167) of 11kv, (20,005) of 415v, and 487,264 customers across the states respectively.
2. **Reliability** is the probability that a system will function as designed under specified conditions for specified period (Brown, 2012).
3. **Power System Reliability** refers to the ability of the system to satisfy the system load requirements as economically as possible and with a reasonable assurance of continuity and quality. In the context of the study, reliability is the probability of the system to provide an acceptable level of continuity and quality of service to customers. Therefore, Reliability has to do with total electric interruptions - complete loss of voltage, not just deformations of the electric sine wave.
4. **Reliability Indices** are used for evaluating components of any Electrical power distribution systems performance. These indices are System Average Interruption Frequency Index (SAIFI), System Average Interruption Duration Index (SAIDI) and Customer Average Interruption Duration Index (CAIDI) (Layton, 2013). They provide a comprehensive indicator of the total reliability of an Electrical distribution system. SAIFI indicates how often an average customer is subjected to sustained interruption over a predefined time interval. SAIDI indicates the total duration of interruption an average customer is subjected for a predefined time interval. CAIDI indicates the average time required to restore the service.
5. **Evaluation** is the process of gathering information about the worth or quality of something as a way of making decisions designed to increase its worth or quality (Okoro & Chikuni, 2013). In the context of this study, therefore Evaluation is defined as a process of assessing the reliability indices and comparing them with the IEEE minimum standards with a view to making value judgement about the quality of distribution of Electrical power which will form the basis for maintenance planning. The importance of power systems reliability evaluation can never be over emphasis. However, it is very important to note that evaluating of the reliability indices in the electrical distribution system will enable KEDCO to plan and design strategies to improve and maintain system performance by comparing it to IEE minimum standards.
6. **Frequency and Duration Outage:** Frequency and duration of outages are relevant measures for reliability in electricity supply systems. If reliability is regarded as a technical restriction, adequate outage indices have to be evaluated. If outages are associated with costs, reliability shall be included within operating costs. The estimation of outage cost mostly used around is the customer survey approach. When comparing among alternatives of approximately equal total costs, the outage indices will be helpful in selection of the best solution (Layton 2013).
 - (a) **SAIDI and SAIFI** – When making reliability investments, reductions in SAIDI and SAIFI are proportional to the number of affected customers. This means projects that affect many customers are preferred to those that affect few customers. However, feeders with many customers typically have better than average reliability, and feeders with few customers have worse than average reliability. Therefore, reliability investment based on SAIFI and SAIDI can drive investments towards densely populated areas where reliability is already satisfactory.
 - (b) **CAIDI** – Although popular with many utilities and regulators, CAIDI is problematic as measure of reliability. This is because, many view CAIDI as a measure of operation efficiency; when utility responds more quickly after a fault, CAIDI will go down. In fact, CAIDI is mathematically equal to SAIDI divided by SAIFI. That is reliability could be improving in both frequency and duration, but CAIDI could be increasing. Because of the above problem, the use of CAIDI is decreasing in today's world. (Elusaki et al 2011)

Aim and objectives of the study

The aim of this study is to determine the reliability indices of the Electrical power distribution system in Kaduna. The study will assess the following indices in line with IEEE P1366:

1. The System Average Interruption Duration Index (SAIDI) of the Electricity distribution system. **IEEE Min.Std 80%**
2. The Customer Average Interruption Duration Index (CAIDI) of the Electricity distribution system. **IEEE Min.Std =70%**
3. The System Average Interruption Frequency Index (SAIFI) of the Electricity distribution system. **IEEE Min.Std >80%**

Research questions

The following research questions are formulated to guide this study;

1. What is the SAIDI of the Electrical power distribution system in Kaduna?
2. What is the CAIDI of the Electrical power distribution system in Kaduna?
3. What is the SAIFI of the Electrical power distribution system in Kaduna?

Methodology

Descriptive Research design was adopted for the study. Descriptive research design involves data collection at points in time and is more likely to identify causal relationships between variables (Shuttleworth, 2008). The study was carried out at two units of Kaduna Network comprised of Kaduna North and South respectively involving all the distribution Engineers/Technicians of the nineteen 33kv feeders. The data collected from Engineers/Technicians and KEDCO comprises of information on each feeder failure event within the period of one year (March, 2017 to February, 2018). The information was recorded in daily hourly report sheet and were translated into a statistical database. The outages were classified as forced and scheduled. Hence, data on failure rates and repair times of component used in the distribution system were compiled for reliability calculations. In addition, data on statistical information consisting of outages arising from the load shedding, system collapse, scheduled or unscheduled maintenance and hourly load shedding on each feeder were collected. These data were used to compute the reliability indices (SAIDI, CAIDI and SAIFI) using equations 1 to 3. The instrument was validated by the Engineers of the Kaduna Electricity Distribution Company (KEDCO). The reliability was found to be reliable as data were secondary source which make it authentic. The total percentage of SAIDI, CAIDI and SAIFI were computed and compared with IEEE Min.Std. SAIFI indicates how often an average customer is subjected to sustained interruption over a predefine time interval whereas SAIDI indicates the total duration of interruption an average customer is subjected for a predefined time interval. CAIDI indicates the average time required to restore the service. The results are shown in Tables 1 to 3.

Results

The data were computed using the following formula for SAIDI, CAIDI and SAIFI.

$$\text{SAIDI} = \Sigma (r_i * N_i) / NT \quad \dots(1)$$

Where: Σ = Summation function. r_i = Restoration time, minutes. N_i = Total number of customers interrupted. NT = Total number of customers served. $\dots(2)$

$$\text{CAIDI} = \Sigma (r_i * N_i) / \Sigma (N_i) \quad \dots(2)$$

Where: Σ = Summation function. r_i = Restoration time, minutes. N_i = Total number of customers interrupted. $\dots(3)$

$$\text{SAIFI} = \Sigma (N_i) / NT$$

Where: Σ = Summation function. N_i = Total number of costumers interrupted. N_T = Total number of customers served.

Table 1: Summary of SAIDI for the Period of (Mar. 2017- Feb 2018) on Each 33kv Feeders

33KVA Stations	SAIDI	IEEE Min.Std 80%	Remarks
AREWA	12.174	"	Less than Min.Std
UNTL	8.157	"	"
NARAYI	18.096	"	"
PAN	7.872	"	"
MAGADISHU	13.552	"	"
INDEPENDENCE	12.726	"	"
U/BORO	18.67	"	"
ABAKPA	11.275	"	"
WATER WORKS	7.018	"	"
NAF	10.771	"	"
DOKA	13.618	"	"
AIRPORT	7.868	"	"
RIGASA	18.929	"	"
U/DOSA	17.537	"	"
KINKINAU	14.745	"	"
GONIN GORA	18.218	"	"
KAWO	17.495	"	"
KUDENDEN	15.775	"	"
DAWAKI ROAD	15.197	"	"
TOTAL AVERAGE	13.677%	"	Less than IEEE Min. Std

Table 1 shows computed total SAIDI percentage across all the 33 kV feeders within Kaduna metropolis. The values presented in the table shows that the entire 19 33kv feeders has their values below IEEE Minimum Standard of > 80%. Water works has the least value of 7% while Rigasa recorded the highest value of 19% with the entire Average percentage value of SAIDI 13.6%.

Table 2: Summary of CAIDI for the Period of (March 2017- Feb 2018) on Each 33kv Feeders

33KVA Stations	CAIDI	IEEE Min.Std 70%	Remarks
AREWA	2.132	"	Less than =70%
UNTL	1.457	"	"
NARAYI	3.044	"	"
PAN	1.409	"	"
MAGADISHU	2.004	"	"
INDEPENDENCE	1.879	"	"
U/BORO	2.681	"	"
ABAKPA	1.754	"	"
WATER WORKS	1.092	"	"
NAF	1.618	"	"
DOKA	2.106	"	"
AIRPORT	1.165	"	"
RIGASA	2.887	"	"
U/DOSA	2.717	"	"
KINKINAU	2.826	"	"

33KVA Stations	CAIDI	IEEE Min.Std 70%	Remarks
GONIN GORA	2.961	"	"
KAWO	2.979	"	"
KUDENDEN	2.933	"	"
DAWAKI ROAD	2.808	"	"
TOTAL AVERAGE	2.23%		Below the Min.Std

Table 2 presents the computed total CAIDI percentage across all the 19 33 kv feeders within Kaduna metropolis. In the table, all the 19 33kv feeders have their values below the IEEE Minimum Standard of 70%. Water works 33 kv feeder and Airport 33 kv feeder recorded the least value of 13% while Goningora, Kawo and Kudanden 33kv recorded high value of 35% this however, indicates that the customers were actually affected with poor electricity supply.

Table 3: Summary of SAIFI for the Period of (March 2017- Feb 2018) on Each 33kv Feeders

33KVA Stations	SAIFI	IEEE Min.Std 80%	Remarks
AREWA	5.755	"	Less than 80%
UNTL	5.838	"	"
NARAYI	6090	"	"
PAN	6.176	"	"
MAGADISHU	6.898	"	"
INDEPENDENCE	6.781	"	"
U/BORO	6.762	"	"
ABAKPA	6.854	"	"
WATER WORKS	6.714	"	"
NAF	6.710	"	"
DOKA	6.571	"	"
AIRPORT	6.738	"	"
RIGASA	6.896	"	"
U/DOSA	6.565	"	"
KINKINAU	5.835	"	"
GONIN GORA	6.141	"	"
KAWO	5.960	"	"
KUDENDEN	5.350	"	"
DAWAKI ROAD	5.622	"	"
TOTAL AVERAGE	6.33%		Less than 80%

Table 3 shows the computed SAIFI across all the 19 33 kV feeders within kaduna metropolis. It was observed that Mogadishu, Independence, U/Boro, Abakpa, Water works, NAF, Airport and Rigasa 33kv feeders has the highest values of above 6% while the rest were less.

Findings of the study

1. The System Average Interruption Duration Index (SAIDI) was found not to be normal in the entire 19 33kv feeders and all the valves and Average are below the IEEE Min. Std of 80%.
2. The Customer Average Interruption Duration Index (CAIDI) was found not operating normal because all the values and Average are below IEEE Min. Std of 70%.
3. The System Average Interruption Frequency Index (SAIFI) was not normal which also indicated that all the valves and Average less than 80% of IEEE Minimum Standard.

Discussion of the findings

The findings on System Average Interruption Duration Index (SAIDI) revealed that the average interruption duration for customers served during a specified time period. This index enables the utility to report how many minutes' customers would have been out of service if all customers were out at one time. The finding on SAIDI revealed that IEEE Minimum Standard was not actually made in which the entire 19 33KV feeders has their values less than 80%. However, Okorie and Abdu (2015) carried out similar research in Kano metropolis in which four indices SAIDI, CAIDI, SAIFI and ASAI were evaluated. But the result of the study shows that all the indices values were below the IEEE Min.Std but it was not compared to make a valid judgment about normality of the above indices (SAIDI). Therefore, there was no any final decision or remark as to whether the SAIDI is operating normal or not.

In the same vein Franklin and Gabriel (2014) carried out research on the five distributions Reliability indices of (SAIDI, CAIDI, SAIFI, ASAI and ASUI). The SAIDI values was found to be within the ranged of IEEE Min. Std and the result of the indices were not compared to the IEEE Min.Std and therefore final decisions or remarked are not established to identify the working conditions of the system. The average value of SAIDI of the entire nineteen 33kv feeders is 13.67% which is less than 80% of IEEE Min.Std, this indicated that the SAIDI system is not operating normal. From the findings on Customer Average Interruption Duration Index (CAIDI); This is the average length of an interruption, weighted by the number of customers affected, for customers interrupted during a specific time period. The index enables utilities to report the average duration of a customer outage for those customers affected. it was observed that the entire 19 33kv feeders have their values below the IEEE Min.Std of 70%. The values ranged from 1% to 3% which is less than 70% of IEEE Min. Std.

Franklin and Gabriel (2014) carried out similar research work in which five distribution indices were analysed and the result shows that the value of CAIDI is below and not compared to IEEE Min.Std, therefore the Decision or Remarks were not made to know whether the system is operating within the limit. It only highlighted the causes of power interruption and recommendation to those problems. However, CAIDI values were below the IEEE Min, Std. CAIDI is customer centre system which deals with the efficiency of electrical supply. Therefore, CAIDI provides the authority, the needs of the customers for efficiency of electrical power supply. The entire average value of CAIDI is less than the IEEE Min.Std of 70%. It has proofed that the CAIDI system is not operating normal. Dorji (2012) conducted a research on Reliability Assessment of Distribution Systems on Wangdue Distribution System in Bhutan, United State and discovered that when CAIDI and SAIDI values are below Minimum Standard it has great effect on the Distribution System.

Based on the findings on System Average Interruption Frequency Index (SAIFI); This is the average number of times that a customer is interrupted during a specified time period. The finding indicates that the entire 19 33kv feeders have values less than 80% of IEEE Min.Std. However, Mogadishu, Independence, U/Boro, Abakpa, Water works, NAF, Airport and Rigasa 33kv feeders have their values high among others which all are less than 80% as compared to IEEE Min.Std. The Average percentage also recorded 6.33% of the entire 19 33kv feeders which is less than 80% of IEEE Min. Std. This indicated that the SAIFI system is not operating normal.

Jibrin and Ekandayo (2013) carried out research work on the Reliability Assessment of 33kv Kaduna Electricity Distribution Feeders. The study highlighted the reliability indices and the causes of power interruption within the distribution feeders. However, no decisions and remarks were made to finalized the normality of the system or not. In a similar study conducted by Okorie and Abdu (2015) title reliability evaluation of power distribution network system in Kano metropolis who reported that the SAIFI is not operating normal as compared with the IEEE min. std. due to the in balance of SAIDI and CAIDI. However, there is no significant power supplied to the consumers which result to load scheduling, age of equipment and component and as well as lack of proper record of all happenings within the distribution system. However, SAIFI would never be stable if the two other indices SAIDI and CAIDI are not performing normal.

References

- Brown, R. E. (2012) *Electric power distribution reliability*. New York: Marcel Dekker.
- Dorji, T. (2009) *Reliability assessment of distribution systems: A case studies on Wangdue Distribution System in Bhutan*. Unpublished Doctoral Degree Thesis, Bhutan University, United States of America.
- Elusaki, J. E., Ajide, O. O., & Diji, J. C. (2011). Challenges of sustaining off-grid power generation in Nigeria rural communities. *African Journal of Engineering Research*, 3 (2), 34-38.
- Franklin, O., & Gabriel, E. (2014). Reliability analysis of power distribution system in Kano metropolis of Nigeria. *International Journal of Electrical and Electronics Science*, 2 (4), 23-24.
- Gupta, J. B. (2012). *A textbook of Electrical Technology for engineering students*. New Delhi, India: S. K. Kataria & Sons.
- Jibril, Y. & Ekundayo, K. R. (2013) Reliability assessment of 33KV Kaduna Electricity Distribution Feeders, Northern Region, Nigeria. *Proceeding of the World Congress on Engineering and Computer Science. Lagos, Nigeria (1)*. pp. 23-25
- KEDCO (2016) *The total energy consumed by KEDCO*. Retrieved on March 16, 2018 from www.kedco.com.
- Labo, H. S. (2010). Current status and future outlook of the transmission network investors, *Forum for the Privatization of PHCN Successor Companies*, 4 (3), 18 -19.
- Laithwaite, E., & Freris, L. L. (2011). *Electric energy: Its generation, transmission and use*. London: McGraw-Hill Book Co.
- Layton, L. (2013). *A handbook on electrical reliability indices calculation*. New York: Wiley & Sons.
- Okorie, P. U., & Abudu, A. I. (2015). Reliability evaluation of power distribution network system in Kano. *International Journal of Engineering and Science* 2 (3), 52-53.
- Okoro, O. I., & Chikuni, E. (2007). 'Power sector reforms in Nigeria: Opportunities and challenges. *Journal of Energy in Southern Africa*, 18 (3), 52 -53.
- Patrick, D. R., & Fardo, S. W. (2009). *Electrical distribution systems* (2ed). London: The Fairmont Press.
- Shuttleworth, M. (2008) *Descriptive research design*. Retrieved on February 10, 2018 from <https://www.explorables.com/descriptive-research-design>.